

TABELA.1 BILANS POWIETRZA WENTYLACYJNO I MOCY CHŁODNICZEJ

NR.	POMIESZCZENIE	POW.	WYS.	KUBATURA	ti ^Z	ti ^L	Qch	LUDZIE	N		W		KOMENTARZ
		m ²	m	m ³	[°C]	[°C]	kW	os.	1/h	m ³ /h	1/h	m ³ /h	
PIWNICA													
-101	Holl	41,10	2,60	106,9	20 ±2°C	w	-	-	2,0	220	2,0	220	CNW1
-102	Komunikacja	11,60	2,60	30,2	20 ±2°C	w	-	-	2,0	60	2,0	60	CNW1
-103	Archiwum I	9,40	2,60	24,4	16±2°C	18±2°C	-	-	4,0	100	4,0	100	CNW1
-104	Archiwum II	11,50	2,60	29,9	16±2°C	18±2°C	-	-	4,0	120	4,0	120	CNW1
-105	Pom. Techniczne	10,40	2,60	27,0	16±2°C	w	-	-	2,0	55	2,0	60	CNW1/WW3
-106	Maszynownia windy	4,40	2,60	11,4	16±2°C	w	-	-	3,0	30	3,0	40	CNW1/WW3
-107	Magazyn I	35,50	2,60	92,3	16±2°C	18±2°C	-	-	4,0	380	4,0	380	CNW1
-108	Magazyn II	34,30	2,60	89,2	16±2°C	18±2°C	-	-	4,0	380	4,0	380	CNW1
-109	Pom. Socjalne	11,50	2,60	29,9	20 ±2°C	w	-	4	4,0	120	-	-	CNW1 / wyw. przez pom. -110 WC
-110	WC	3,90	2,60	10,1	20 ±2°C	w	-	-	-	-	12,0	120	Nawiew z pom socjal.-109 / WW2
PARTER													
002	Holl	50,80	3,19	162,1	20 ±2°C	24 ±2°C	5,29	10,0	2,8	450	2,8	450	CNW1 / KW1.3 / KZ1
003a	Biuro	10,40	3,19	33,2	20 ±2°C	24 ±2°C	1,58	2,0	-	-	-	-	KW1.2 / KZ1
003b	Biuro	24,10	3,19	76,9	20 ±2°C	24 ±2°C	2,54	3,0	-	-	-	-	KW1.1 / KZ1
005	Biuro	20,40	3,19	65,1	20 ±2°C	24 ±2°C	2,47	3,0	-	-	-	-	KW1.4 / KZ1
006	Strażnica	11,30	3,19	36,0	20 ±2°C	24 ±2°C	1,56	2,0	-	-	-	-	KW1.5 / KZ1
008	Biuro	53,70	3,19	171,3	20 ±2°C	24 ±2°C	5,51	8,0	-	-	-	-	KW1.7 / KZ1
009	Biuro	14,60	3,19	46,6	20 ±2°C	24 ±2°C	1,63	2,0	-	-	-	-	KW1.6 / KZ1
PIĘTRO													
101	Holl	52,30	3,00	156,9	20 ±2°C	w	w	-	2,0	320	2,0	320	CNW1
102	Biuro	60,30	3,00	180,9	20 ±2°C	24 ±2°C	5,77	9,0	-	-	-	-	KW 1.13 / KZ1
103	Biuro	15,00	3,00	45,0	20 ±2°C	24 ±2°C	1,77	2,0	-	-	-	-	KW 1.14 / KZ1
106	Biuro	16,50	3,00	49,5	20 ±2°C	24 ±2°C	1,60	2,0	-	-	-	-	KW 1.8 / KZ1
107	Biuro	20,40	3,00	61,2	20 ±2°C	24 ±2°C	2,57	3,0	-	-	-	-	KW 1.9 / KZ1
108	Skretariat	14,20	3,00	42,6	20 ±2°C	24 ±2°C	1,37	1,0	-	-	-	-	KW 1.10 / KZ1
109	Gabinet Dyrektora	21,30	3,00	63,9	20 ±2°C	24 ±2°C	2,06	2,0	-	-	-	-	KW 1.11 / KZ1
110	Sala konferencyjna	34,60	3,00	103,8	20 ±2°C	24 ±2°C	4,75	10,0	-	-	-	-	KW 1.12 / KZ1
PODDASZE													
201	Holl	40,90	2,90	118,6	20 ±2°C	w	w	-	2,0	240	2,0	240	CNW1
203	Serwerownia	12,60	2,90	36,5	20 ±2°C	24 ±2°C	5,72	1,0	-	-	-	-	KW2 / KZ2
206	Biuro	42,90	2,90	124,4	20 ±2°C	w	4,61	4,0	-	-	-	-	KW 1.16 / KZ1
207	Biuro	40,00	2,90	116,0	20 ±2°C	w	5,84	6,0	-	-	-	-	KW 1.15 / KZ1